



中国认可
国际互认
检测
TESTING
CNAS L5772

TEST REPORT

EN 149:2001+A1:2009 protective devices. Filtering half masks to protect against particles. Requirements, testing, marking

Product: Particle filtering half mask
Report No.: PTC20061603101C-EN01V01
Client: Dongguan Zhijie Automation Equipment Co.,Ltd.
Client Address: Room 301, Building 3, No. 5 Xinji Road, Nancheng Street, Dongguan City, Guangdong Province, China
Manufacturer: Dongguan Zhijie Automation Equipment Co.,Ltd.
Manufacturer Address: Room 301, Building 3, No. 5 Xinji Road, Nancheng Street, Dongguan City, Guangdong Province, China
Contact: Junchen yan
Model(s): SYA95
Classification: FFP2
Date of Tests: Jun.17,2020 ~Jul.02,2020

Signed for and on Behalf of PTC

Prepare by:

Checked by:



Arme

Jue

niya

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 2 of 13

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.

The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 3 of 13

Summary of assessment

| Clause | Assessment |
|---|------------|
| 7.3 Visual inspection | Not tested |
| 7.4 Packaging | PASS |
| 7.5 Material | PASS |
| 7.6 Cleaning and disinfecting | N/A |
| 7.7 Practical performance | PASS |
| 7.8 Finish of parts | PASS |
| 7.9.1 Total inward leakage | PASS |
| 7.9.2 Penetration of filter material | PASS |
| 7.10 Compatibility with shin | PASS |
| 7.11 Flammability | PASS |
| 7.12 Carbon dioxide content of the inhalation air | PASS |
| 7.13 Head harness | PASS |
| 7.14 Field of vision | PASS |
| 7.15 Exhalation valve | N/A |
| 7.16 Breathing resistance | PASS |
| 7.17 Clogging | N/A |
| 7.18 Demountable parts | PASS |
| 9 Marking | Not tested |

Remark:

PASS: comply with requirement of standard

N/A: not application

Not tested: the clause were not required

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 4 of 13

Test Result:

| Requirement | Test Result | Conclusion |
|--|--|-------------------|
| 7.3 Visual inspection The visual inspection shall also include the marking and the information supplied by the manufacturer. | Not tested | Not tested |
| 7.4 Packaging Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use. | In accordance with the requirement. | Pass |
| 7.5 Material Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used. Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer. After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps. When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse. | No mechanical failure after undergoing the conditioning described in 8.3.1, No collapse when conditioned in accordance with 8.3.1 and 8.3.2. | Pass |
| 7.6 Cleaning and disinfecting If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. | Single shift use only | N/A |
| 7.7 Practical performance The particle filtering half mask shall undergo practical performance tests under realistic conditions | No imperfections | Pass |
| 7.8 Finish of parts Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs. | No sharp edges or burrs. | Pass |

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 5 of 13

7.9.1 Total inward leakage

For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than 25 % for FFP1, 11 % for FFP2, 5 % for FFP3

FFP2, Test results are shown in Annex A Table 7.9.1-A&B

Pass

and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than 22 % for FFP1, 8 % for FFP2, 2 % for FFP3.

7.9.2 Penetration of filter material

The penetration of the filter of the particle filtering half mask shall meet the requirements of Table 1.

| | Sodium chloride test 95 l/min | Paraffin oil test 95 l/min |
|------|----------------------------------|-------------------------------|
| FFP1 | ≤ 20% | ≤ 20% |
| FFP2 | ≤ 6% | ≤ 6% |
| FFP3 | ≤ 1% | ≤ 1% |

FFP2, Test results are shown in Annex A Table 7.9.2.

Pass

7.10 Compatibility with skin

Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.

No irritation or any other adverse effect to health.

Pass

7.11 Flammability

When tested, the particle filtering half mask shall not burn or not to continue to burn for more than 5 s after removal from the flame.

Test results are shown in Annex A Table 7.11.

Pass

7.12 Carbon dioxide content of the inhalation air

The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1,0 % (by volume)

Test results are shown in Annex A Table 7.12.

Pass

7.13 Head harness

The head harness shall be designed so that the particle filtering half mask can be donned and removed easily.

Head harness can be donned and removed easily, adjustable or self-adjusting and have sufficiently robust to hold the

Pass

The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 http:// www.ptc-testing.com



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 6 of 13

device.

particle filtering half mask firmly.

7.14 Field of vision

The field of vision is acceptable if determined so in practical performance tests.

Pass the practical performance tests.

Pass

7.15 Exhalation valve

A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations.

If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9.

No exhalation valve

N/A

Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30 s.

When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10 N applied for 10 s.

7.16 Breathing resistance

| Classification | Maximum permitted resistance (mbar) | | |
|----------------|-------------------------------------|----------|------------|
| | Inhalation | | Exhalation |
| | 30 l/min | 95 l/min | 160 l/min |
| FFP1 | 0.6 | 2.1 | 3.0 |
| FFP2 | 0.7 | 2.4 | 3.0 |
| FFP3 | 1.0 | 3.0 | 3.0 |

FFP2. Test results are shown in Annex A Table 7.16.

Pass

7.17 Clogging

7.17.2 Breathing resistance

Valved particle filtering half masks:

After clogging the inhalation resistances shall not exceed:

FFP1: 4 mbar, FFP2: 5 mbar, FFP3: 7 mbar at 95L/min continuous flow

The exhalation resistance shall not exceed 3 mbar at 160 L/min continuous flow

Single shift use only.

N/A

Valveless particle filtering half masks

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 7 of 13

After clogging the inhalation and exhalation resistances shall not exceed:
FFP1: 3 mbar, FFP2: 4 mbar, FFP3: 5 mbar at 95L/min continuous flow

7.17.3 Penetration of filter material

| | Sodium chloride test 95 l/min | Paraffin oil test 95 l/min |
|------|----------------------------------|-------------------------------|
| FFP1 | ≤ 20% | ≤ 20% |
| FFP2 | ≤ 6% | ≤ 6% |
| FFP3 | ≤ 1% | ≤ 1% |

7.18 Demountable parts

All demountable parts (if fitted) shall be readily connected and secured, where possible by hand

Comply

Pass

9 Marking

9.1 Packaging

The following information shall be clearly and durably marked on the smallest commercially available packaging or legible through it if the packaging is transparent.

9.1.1 The name, trademark or other means of identification of the manufacturer or supplier.

9.1.2 Type-identifying marking.

9.1.3 Classification

The appropriate class (FFP1, FFP2 or FFP3) followed by a single space and then: "NR" if the particle filtering half mask is limited to single shift use only. Example: FFP3 NR, or "R" if the particle filtering half mask is re-usable.

Not tested

Not tested

Example: FFP2 R D.

9.1.4 The number and year of publication of this European Standard.

9.1.5 At least the year of end of shelf life. The end of shelf life may be informed by a pictogram as shown in Figure 12a, where yyyy/mm indicates the year and month.

9.1.6 The sentence 'see information supplied by the manufacturer', at least in the official language(s) of the country of destination, or by using the pictogram as shown in Figure 12b.

9.1.7 The manufacturer's recommended conditions of storage (at least the temperature and humidity) or equivalent pictogram, as shown in Figures 12c and 12d.

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.

The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 http:// www.ptc-testing.com



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 8 of 13

9.1.8 The packaging of those particle filtering half masks passing the dolomite clogging test shall be additionally marked with the letter "D". This letter shall follow the classification marking preceded by a single space.

9.2 Particle filtering half mask

Particle filtering half masks complying with this European Standard shall be clearly and durably marked with the following:

9.2.1 The name, trademark or other means of identification of the manufacturer or supplier.

9.2.2 Type-identifying marking.

9.2.3 The number and year of publication of this European Standard.

9.2.4 Classification

The appropriate class (FFP1, FFP2 or FFP3) followed by a single space and then: "NR" if the particle filtering half mask is limited to single shift use only. Example: FFP3 NR, or "R" if the particle filtering half mask is re-usable. Example: FFP2 R D.

9.2.5 If appropriate the letter D (dolomite) in accordance with clogging performance. This letter shall follow the classification marking preceded by a single space.

9.2.6 Sub-assemblies and components with considerable bearing on safety shall be marked so that they can be identified.

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 9 of 13

Annex A: Summarization of Test Data

Table 7.9.1-A: Inward Leakage Test Data

Test specification: EN 149:2001+A1:2009 Clause 8.5

| Subject | Sample No. | Condition | Walk (%) | Head Side/side (%) | Head up/down (%) | Talk (%) | Walk (%) | Mean (%) |
|----------------|------------|-----------|----------|--------------------|------------------|----------|----------|----------|
| Lv Cuiling | 1 | A.R | 1.30 | 4.26 | 4.61 | 9.35 | 4.38 | 4.78 |
| Li Meng shuang | 2 | A.R | 10.99 | 10.7 | 11.4 | 18.91 | 10.8 | 12.56 |
| Zhong Tianzhen | 3 | A.R | 6.55 | 4.73 | 4.82 | 8.9 | 7.4 | 6.48 |
| Xu Qiang | 4 | A.R | 0.78 | 1.67 | 2.41 | 4.32 | 3.46 | 2.53 |
| Ma Li | 5 | A.R | 7.55 | 2.87 | 14.07 | 10.69 | 8.16 | 8.67 |
| Chen Xianfeng | 6 | T.C | 1.01 | 0.08 | 1.09 | 4.89 | 1.61 | 1.74 |
| Chen Xiaoyu | 7 | T.C | 1.49 | 2.13 | 1.22 | 4.54 | 2.55 | 2.39 |
| Zhuo Cuiyan | 8 | T.C | 5.58 | 4.39 | 3.92 | 4.08 | 1.98 | 3.99 |
| Chen Guanpeng | 9 | T.C | 1.64 | 1.66 | 2.05 | 9.66 | 4.22 | 3.85 |
| Zhang He | 10 | T.C | 1.89 | 2.58 | 1.90 | 2.80 | 2.64 | 2.36 |

Table 7.9.1-B: Facial dimension

| Subject | Face Length | Face Width | Face Depth | Mouth Width |
|----------------|-------------|------------|------------|-------------|
| Lv Cuiling | 113 | 139 | 104 | 53 |
| Li Meng shuang | 120 | 135 | 112 | 55 |
| Zhong Tianzhen | 108 | 135 | 106 | 56 |
| Xu Qiang | 120 | 150 | 120 | 70 |
| Ma Li | 130 | 170 | 130 | 80 |
| Chen Xianfeng | 110 | 160 | 90 | 40 |
| Chen Xiaoyu | 115 | 145 | 110 | 50 |
| Zhuo Cuiyan | 103 | 146 | 100 | 50 |
| Chen Guanpeng | 110 | 145 | 95 | 40 |
| Zhang He | 144 | 141 | 101 | 54 |

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 10 of 13

Table 7.9.2: Penetration of filter material

Test specification: EN 149:2001+A1:2009 Clause 8.11

| Aerosol | Condition | Sample No. | Penetration (%) | Assessment |
|----------------------|---|------------|-----------------|------------|
| Sodium chloride test | As received | 11 | 0.2 | FFP2, Pass |
| | | 12 | 0.2 | |
| | | 13 | 0.2 | |
| | Simulated wearing treatment | 14 | 0.0 | |
| | | 15 | 0.0 | |
| | | 16 | 0.0 | |
| | Mechanical strength + Temperature conditioned | 17 | 0.18 | |
| | | 18 | 0.21 | |
| | | 19 | 0.22 | |
| Paraffin oil test | As received | 20 | 0.2 | |
| | | 21 | 2.3 | |
| | | 22 | 0.4 | |
| | Simulated wearing treatment | 23 | 0.96 | |
| | | 24 | 0.31 | |
| | | 25 | 0.33 | |
| | Mechanical strength + Temperature conditioned | 26 | 1.87 | |
| | | 27 | 1.32 | |
| | | 28 | 0.88 | |

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 11 of 13

Table 7.11: Flammability

Test specification: EN 149:2001+A1:2009 Clause 8.6

| Condition | Sample No. | Result | Assessment |
|-------------------------|------------|---------|------------|
| As received | 29 | No burn | Pass |
| | 30 | No burn | |
| Temperature conditioned | 31 | No burn | |
| | 32 | No burn | |

Table 7.12: Carbon dioxide content of the inhalation air

Test specification: EN 149:2001+A1:2009 Clause 8.7

| Condition | Sample No. | Result (%) | | Assessment |
|-------------|------------|------------|---------------------|------------|
| As received | 33 | 0.28 | Mean value: 0.27 | Pass |
| | 34 | 0.26 | | |
| | 35 | 0.27 | | |

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 12 of 13

Table 7.16: Breathing resistance (mbar)

Test specification: EN 149:2001+A1:2009 Clause 8.9

| | | | | | | | | | | | | | | | | | |
|-----------------------------|------------|----------|------|-----|-----|-----|-----|------|-----|-----|-----|-----|------|-----|-----|-----|--|
| As received | Flow Rate | | 36 | | | | | 37 | | | | | 38 | | | | |
| | Inhalation | 30 l/min | 0.4 | | | | | 0.5 | | | | | 0.5 | | | | |
| | | 95 l/min | 1.6 | | | | | 1.4 | | | | | 1.5 | | | | |
| Exhalation | 160 l/min | A | B | C | D | E | A | B | C | D | E | A | B | C | D | E | |
| | | 2.7 | 2.7 | 2.5 | 2.6 | 2.4 | 2.5 | 2.7 | 2.4 | 2.5 | 2.4 | 2.2 | 2.6 | 2.5 | 2.5 | 2.5 | |
| Simulated wearing treatment | Flow Rate | | 39 | | | | | 40 | | | | | 41 | | | | |
| | Inhalation | 30 l/min | 0.39 | | | | | 0.39 | | | | | 0.47 | | | | |
| | | 95 l/min | 1.30 | | | | | 1.30 | | | | | 1.32 | | | | |
| Exhalation | 160 l/min | A | B | C | D | E | A | B | C | D | E | A | B | C | D | E | |
| | | 2.4 | 2.4 | 2.5 | 2.4 | 2.4 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.4 | 2.6 | 2.6 | 2.5 | 2.6 | |
| Temperature conditioned | Flow Rate | | 42 | | | | | 43 | | | | | 44 | | | | |
| | Inhalation | 30 l/min | 0.47 | | | | | 0.48 | | | | | 0.43 | | | | |
| | | 95 l/min | 1.36 | | | | | 1.43 | | | | | 1.39 | | | | |
| Exhalation | 160 l/min | A | B | C | D | E | A | B | C | D | E | A | B | C | D | E | |
| | | 2.4 | 2.4 | 2.4 | 2.3 | 2.3 | 2.3 | 2.4 | 2.4 | 2.4 | 2.4 | 2.3 | 2.6 | 2.3 | 2.3 | 2.2 | |
| Assessment | Pass | | | | | | | | | | | | | | | | |

A: Facing directly ahead B: Facing vertically upwards C: facing vertically downwards

C: Lying on the left side D: Lying on the right side

Remark: This report supersedes all previous documents bearing the test report number PTC20061603101C-EN01.

Report number PTC20061603101C-EN01 was invalid.

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)





TEST REPORT

Report No.:PTC20061603101C-EN01V01

Issue Date: Jul.14, 2020

Page 13 of 13

Photo(s) of Sample:



End of report

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)